

RV Park Electrical Pedestal Inspection Checklist

Quarterly, annual, storm-event · Campground Management · campgroundmanagement.com

This checklist is for trained electrical-aware staff or a licensed electrician. If anything below feels outside your training, stop and bring in a pro. Pedestals carry up to 240 volts at 50 amps. Mistakes here are not paperwork mistakes.

Park	_____	Inspection Date	_____
Inspector Name	_____	License # (if applicable)	_____

Sites Inspected (#)

Quarterly Per-Pedestal Check (each pedestal, every quarter)

- Visual inspection: housing intact, no cracks, no rust-through
- Cover and gasket present and seal intact
- All receptacles (50A, 30A, 20A) free of carbon scoring
- Cover plates on unused receptacles secure
- Pedestal grounding wire visible and intact at base
- GFCI on 20A duplex tests good (press TEST, then RESET)
- Breakers fully seated, no signs of overheating discoloration
- Pedestal label / site number legible
- Walking-distance vegetation cleared from base

Annual Per-Pedestal Check (every pedestal, once a year)

- Thermal scan (infrared camera) of breakers and connections under load
- Voltage test at receptacle: 30A (120V +/- 5%), 50A (240V +/- 5%)
- Tighten lug terminations at main lug per torque spec on breaker label
- Check torque on grounding electrode at pedestal base
- Confirm GFCI trip threshold (5 mA +/- on calibrated tester)
- Verify breaker label matches actual amperage of the receptacle below it
- Replace cover gasket if hardened or cracked
- Inspect underground feeder lead for damage at conduit entry

Annual Park-Wide Electrical (licensed electrician)

- Service entrance and main panel inspection
- Sub-panel inspection at every distribution point
- Tighten all main-panel and sub-panel lugs to spec
- Thermal scan main and sub-panels under full load
- Verify ground grid integrity (ground rod resistance test)
- Verify neutral-to-ground bond at service only, not at sub-panels
- Inspect transformer pad (if owned by park) for oil leaks and rust
- Test main breaker trip (with utility coordination)
- Update park electrical drawing with any changes
- File annual inspection report with park records

Post-Storm Event Check (after any storm with wind 50+ MPH, hail, or strike)

- Visual inspection of every pedestal cover
- Voltage test at every 50A receptacle
- Re-test every GFCI
- Inspect overhead and underground feeders for damage
- Inspect ground rods and bonds (especially after a strike)
- Document any pedestal taken out of service
- Tag any failed pedestal with red lockout-tagout, do not re-energize

Heavy-Draw Rig (40+ ft, dual AC) Reliability Notes

Large rigs with two roof air conditioners can pull 35-40 amps on a 50-amp service at peak. The pedestals that fail under that load tend to fail at three specific points:

- **The 50A receptacle face.** Corrosion or carbon scoring at the spade contacts causes voltage drop and heat. Visual inspection catches this. Replace any receptacle showing scoring, do not just clean it.
- **The breaker lug torque.** A loose lug heats up under load, then loosens further. Annual torque check, with the label torque spec, fixes it before it becomes a thermal event.
- **The underground feeder run length.** Long runs to back sites drop voltage. If a back-row 50A site reads 224V under load instead of 240V, the run is too long for the conductor size and needs upsizing.

Disclaimer. This template is provided by Campground Management as an editable starting point for park operators. It is not legal advice. Eviction, tenancy, liability, employment, and waiver law varies by state, by county, and by the operating structure of your park. Have a licensed attorney in your jurisdiction review and adjust this document before using it with guests, workers, or third parties.

© Campground Management · Free to use, modify, and brand for your park. Republishing the template for resale is not permitted.